

NIT No.	Name of the Work.	Earnest Money	Place of Work.
14	Conversion and modification 1(one) Room of size (3.00x2.40x 33.00 (H)mtr. into Cold Room by installing of Air Cooler Refrigeration Machinery and insulating the Room with EPS insulation attached to existing Cold Storage at Matigara Sericulture Complex, Darjeeling (Having temperature from 2.5°C to 25°C).	5.00% (Five point zero zero) percent of the Quoted value.	Matigara Sericulture Complex, Siliguri, Darjeeling.

Quotation Papers (NIQ, Priced Schedule & Form 2911(ii) etc.) may be obtained/downloaded from Website : seriwb.gov.org at free of cost.

Quotation should be submitted/dropped in the Box kept at Head Quarters, Kolkata and papers should be arranged in the following manner.

Last date and time of submission of Quotation.	15.01.2018 upto 3-00 p.m, at Headquarter, Kolkata.
Date of time of opening of Quotation.	15.01.2018 at 3-30 p.m. at Headquarter, Kolkata.

Envelope - I, should be super scribed as Technical Bid for N.I.Q.No....., Sl.No. of work. Name of the Agency that it should contain Self Attested PAN Card. Last I.T. Return, GST IN Registration, P.T. Challan, Credential (Similar nature of work at about 60% of Tender value), E.M.D., Electrical & Supervisory License and sealed.

Envelope - II, should be super scribed as Financial Bid for N.I.Q. No....., Sl.No. of Work, Name of Agency and should contain filed on 2911 (ii) quoting in Rate and Sealed.

2(two) Envelopes as noted above (I & II) should be put in a bigger Envelope and sealed. Agency should write clearly N.I.Q. No..... Name of Work, SL. No. and Name of Agency on this Envelope and drop the same as per scheduled mentioned in this N.I.Q.


The Technical Bid will be opened first. The Financial Bid will be opened only if the Technical Bid is found acceptable.

Labour Cess will be deducted from Bill value as per Govt. Rules. All original copies are to be shown for verification. The details may be seen in the Office of the Commissioner of Textiles (Sericulture), West Bengal 45, Ganesh Ch. Avenue (2nd floor) , Kolkata - 13 on any working days and in website : seriwb.gov.org. The Commissioner of Textiles (Sericulture), West Bengal reserves the right to reject/accept all the applications without showing any reasons thereof. If any date as above happens to be holiday the next working day will be considered as stipulated date.

N.S.C./K.V.P. will not be accepted as Earnest Money. Only the bank Draft of a Nationalized Bank will be considered as earnest money.

Acceptance of lowest Tender is not obligatory.


Notwithstanding anything contained in this Notice Inviting Quotation, the other terms and conditions and special terms and conditions will remain binding upon all concerned


Executive Engineer,
Directorate of Textiles(Sericulture),
West Bengal. 27/12/2017.
 Dated

Memo.No. 1994(3) /ENG/CIVIL/PCR/DARJ(P)/1(Vol.-I),

Copy forwarded for information & necessary action to :-

1. The Joint Director of Textiles (Sericulture), North Zone, Siliguri, Darjeeling.
2. The Notice Board of this Directorate, Headquarters, Kolkata.
- ✓ 3. The Website of this Directorate of Textiles (Sericulture), West Bengal.


Executive Engineer,
Directorate of Textiles(Sericulture),
West Bengal.

Specification for conversion of one room to a new cold room enable to maintain a temperature of 205° C or above.

(Room size - 3.00 x 3.70 x 3.00(H))


Insulation works

1. Totally PVC Glass wool Insulation room in all sides, Wall and roof.

60 mm overall thickness, with 1 mm ^{thick} Alumi Sheet, Pasted with Glass wool, and break on Per Relevant IS Specifications.

Refrigeration Work

1. R-404A outdoor type condensing unit, compressing of 3 Ton 3 phase Danfoss / Emersion make scroll compressure air cool condencer with all fans (motor type) pressure switch relay coductors, Capacitor and internal wiring interconnecting pipe in PVC all the metal casing and mounted on wall or floor make (Cooling condencer and Outdoor Unit will be all brass pipe).
2. R-404A evaporator uint complete with direct expansion cooling coil 2 nos. Axial flow fans with motor capillary drain pan with pipe, interconnecting pipe etc. all assemble in a metal sheet and mounted on wall or roof supported by M.S. bracket.
3. Refrigeration pipe between condensing and end evapour units including interconnecting pipeing between refrigeration system component and insulating of pipeing.
4. Digital Temperature control board with display for Temperature all time show.



Executive Engineer

Directorate of Textiles (Sericulture)
West Bengal